

तार : श्रोरगर

Telegrams: "ORGAR"

टेलीफोन : गाजियाबाद
Telephone : Ghaziabad{ 710910
710911
710912

Telex : 031-65427

प्रेषक : महाप्रबन्धक

FROM : THE GENERAL MANAGER



नं. 10/C.M.P./2005. Dt. 30-11-2005

भारत सरकार

GOVERNMENT OF INDIA

रक्षा मन्त्रालय

MINISTRY OF DEFENCE,

आर्डनेंस फैक्टरी बोर्ड

ORDNANCE FACTORY BOARD,

आर्डनेंस फैक्टरी, मुरादनगर

ORDNANCE FACTORY,

MURADNAGAR-201 206.

Dated..... 30-11-2005 19

To

M/S Southern Cooling Tower
Pvt Ltd. KolkataTo whom it may ConcernSub:- ~~Ref.~~ Installation of Cooling TowerRef:- (1) S.O No 12430266 Dt 08-12-2005
(11) Firm Representative Visit on Dt 23-11-2005

It is certified that 01 No Cooling tower which has been received in this factory against referred S-order. & it has been installed in water recirculation unit of Arc Furnace in H.S.F Sec in the presence of Firm Representative Mr Sujit Kumar Das on Dt 29-11-2005.

The motor of the Cooling Tower has been tested by E.M Sec and found Satisfactory.

The function of the Cooling Tower could not be checked due to incomplete electrical connection.

Shri Sujit Kumar Das has reported to this factory on Dt 23-11-2005 and is being released from O.F.M. on Dt 30-11-2005 after Noon.

(Atul Dasumaty)

JtGM/CE

General Manager